



ESCALATOR DATA SHEET CHECKLIST

GENERAL	Date:	Unit Name:
	Unit Number:	Speed:
	Address:	ED Installer:
	City:	Elevator Constructor:

Internal Inspections and Tests	Main Disconnect Switch				Motor Data Plate			
	Volts:		Fuse:		Volts:		Amps:	
	Running Volts:				Running Amps:			
	Upper Landing Tests			Status	Lower Landing Tests			Status
	Machine Space Access				Pit Space Access			
	Machine Space Lighting				Pit Space Lighting			
	Machine Space Receptacle				Pit Space Receptacle			
	Machine Space Guards				Pit Space Guards			
	Landing Plate Stop Switch				Pit Stop Switch			
	Missing Step Device				Landing Plate Stop Switch			
	Motor Stop Switch				Missing Step Device			
	Emergency Stop Switch				Emergency Stop Switch			
	Step Level Switch				Step Chain Tension Switch			
					Step Level Switch			
	Skirt Devices		L	R	Skirt Devices		L	R
	Handrail Entry		L	R	Handrail Entry		L	R
	Handrail Speed		L	R	Step Up-Thrust		L	R
	Upper Comb-Step Impact Device				Lower Comb-Step Impact Device			
	H/L <1780n	H/R <1780n	H/M <3560n	V/M <670n	H/L <1780n	H/R <1780n	H/M <3560n	V/M <670n
	Inspection Control Devices				Reversal Stop Switch			
	Start Switches				Governor/Overspeed Monitoring ≤ 140			
	Contactor Failure Redundancy				Stopping Distance		▲	▼
					Broken Step Chain/Treadway Device			

Where there is a conflict between this Guideline and the Act and Regulations the regulations shall prevail.



- Page 2 - Escalator Data Sheet Checklist

Internal Tests Continued	Manual Reset After Safety Switches		Clearance Skirt/Step	$\leq 5 \text{ mm}$	
	Main Drive Shaft Brake		Clearance Step/Step	$\leq 6 \text{ mm}$	
	Demarcation	2 green lights	Audible Alarm		
	Flat Steps	2-4 steps	Wiring/Listing/Certification/Labeling		
	Step Width:	560 < W > 1020 mm	Brake Data Plate		
	Step Depth:	> 400 mm	Code Data Plate		
	Step Height:	< 220 mm	Out Door Protection		
	Handrail Height	900-1000 mm	Heaters, cover, drain		
	Step / Skirt Performance Index Test Results			Left Skirt	Right Skirt

External Inspection	Guards @ Ceiling Intersection	< 350 mm	Deck Barricades	> 125 mm	
	Anti-Slide Devices		Entrance & Egress Head Room	2130 mm	
	Egress and Safety Zone		Combplates		
	Walk Well Guards		Caution Signs		
	Floor Opening Protection		Lighting, Illumination level		
	Egress Restriction Device				

Where there is a conflict between this Guideline and the Act and Regulations the regulations shall prevail.

FOIP "The personal information is being collected in support of the administration of the *Safety Codes Act*. The authority to collect the personal information is made pursuant to section 33(c) of the *Freedom of Information and Protection of Privacy (FOIP) Act*, and will be managed in accordance with the privacy provisions of the *FOIP Act*. If you have any questions regarding the collection of this personal information, please contact the Alberta Elevating Devices and Amusement Rides Safety Association at 104, 8616 51 Ave, Edmonton, T6E 6E6 or by telephone at 1-800-222-7281.